

# Fire Rating Information Sheet

## Architectural Fusions

	Class A Fire Rating		UL 10B - Standard for Fire Tests of Door Assemblies
	UL-723 Test	ASTM E-84 Test	UL 10C - Standard for Positive Pressure Fire Tests of Door Assemblies
Belbien	All Belbien Patterns, except MT and SG		3 hour rating for application to wood, composite and metal covered fire door surfaces as well as door frames and glazing material
Reatec		All Reatec patterns	90 minutes rating for application to hollow metal and metal composite fire door surfaces as well as door frames
LG		All LG patterns except NC	45 minute rating for application to wood covered composite or wood core type fire door surfaces as well as door frames

## Architectural Fusions - Reatec tested when applied to 1/8" Sintra panel

Test Specimen	Flame Spread Index	Smoke Developed Index
Fiber-Reinforced Cement Board, Grade II	0	0
Red Oak Flooring	100	100
Reatec 14TC7224 Self-Adhered to 1/8" Sintra (flame spread index rating of 0-25 is Class A Fire-rated)	25	350

